

B/E Aerospace's Detention Pond was Originally Designed Incorrectly

- At Hearing SKWC showed that PDS had erred when it approved the original B/E Aerospace detention pond circa 2011.
- However, because SKWC did not appeal the 2011 permit, the Hearing Examiner would not consider that the Pond should be brought up to the design requirements of SNOCO's 2010 *Drainage Manual*.
- Only the footprint of the pond was designed to current standards and the rest of the site uses a vault designed to 1992 standards.